

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2170033

Ordering firm: KOPOS KOLÍN a.s.
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.
Havlíčkova 432, 280 94 Kolín IV, Czech Republic

Name of product: Socket-outlet QUADRO 45x45

Trade name:

Type of product: QS 45x45, QS 45x45 C

Rating: 16 A, 250 V ~, IP20

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „EŠC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 701701-01/01 of: 17.05.2017

A sample of the product was tested and found to be in conformity with:
ČSN IEC 60884-1:03+1:04+2:15+A1:14+A2:14

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 700539-01 of 11.04.2017
- the Agreement on the use of the ESC Mark No. 701701 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

26.05.2017

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



701701-01